

COLLEGE of CHARLESTON

ENVIRONMENTAL
HEALTH AND SAFETY

Facility: _____

Location: _____

EYEWASH AND DRENCH HOSE UNITS WEEKLY INSPECTION LOG

- Weekly activate eyewash station (or drench hose) until water runs clear to make sure it is operating properly and organisms are flushed from the pipes. Check/replace gravity-fed eyewash units per manufacturer's requirements.
- Clean end caps and faucet head with biocide
- Document date equipment was activated and inspected.
- Person documenting must initial. Print name on back of form.
 - Report problems immediately to supervisor. Supervisor (or his/her designee) must report any problems to Physical Plant online
<https://mcc.battery.cofc.edu/cr/secure/splash.xhtml?jsessionid=E92BEA7BE41C3F46EEF5DC9C0F64272A> or by telephone call (X3-5550).

Week	Week of/ Date	Initials		Week	Week of/ Date	Initials
1				27		
2				28		
3				29		
4				30		
5				31		
6				32		
7				33		
8				34		
9				35		
10				36		
11				37		
12				38		
13				39		
14				40		
15				41		
16				42		
17				43		
18				44		
19				45		
20				46		
21				47		
22				48		
23				49		
24				50		
25				51		

52

Print Name

[illegible]

Personnel working in this area has been instructed on the location and use of the any and all applicable eyewash fountain, emergency shower, drench hose and/ or gravity-fed eyewash units.